



**Designation: A 377 – 9903**

## **Standard Index of Specifications for Ductile-Iron Pressure Pipe<sup>1</sup>**

This standard is issued under the fixed designation A 377; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

### **1. Scope**

1.1 This index identifies specifications that cover ductile-iron pressure pipe suitable for carrying water and other liquids under pressure.

NOTE 1—The text of this standard references notes and footnotes which provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the standard.

### **2. Method of Designation**

2.1 The ASTM designation for these specifications is not sufficient to describe the particular items which a purchaser may desire; therefore, the ANSI designation for the applicable American National Standards shown in Section 3 shall be specified in the inquiry, contract, and order.

### **3. Reference Specifications**

3.1 Ductile iron pipe furnished in accordance with this index are covered by the following American National Standards:

---

<sup>1</sup> This index is under the jurisdiction of ASTM Committee A-4 A04 on Iron Castings and is the direct responsibility of Subcommittee A04.12 on Pipes and Tubes. Current edition approved ~~October 10, 1999~~; Dec. 1, 2003. Published ~~November 1999~~; January 2004. Originally published as A 377 – 54; approved in 1954. Last previous edition ~~A 377 – 95<sup>ε</sup>~~; approved in 1999 as A 377 – 99.

ANSI/AWWA C151/A21.51, Ductile-Iron Pipe, Centrifugally Cast for Water,<sup>2,3</sup>

3.2 Other American National Standards relating to ductile-iron pipe are the following:

ANSI/AWWA C104/A21.4, Cement-Mortar Lining for Ductile-Iron Pipe and Fittings for Water,<sup>2,3</sup>

ANSI/AWWA C105/A21.5, Polyethylene Encasement for Ductile-Iron Pipe Systems,<sup>2,3</sup>

ANSI/AWWA C106/A21.50, Thickness Design of Ductile-Iron Pipe,<sup>2,3</sup>

ANSI/AWWA C110/A21.10, Ductile-Iron and Gray-Iron Fittings, 3 in. through 48 in. (76 mm through 1219 mm) for Water,<sup>2,3</sup>

ANSI/AWWA C111/A21.11, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings,<sup>2,3</sup>

ANSI/AWWA C115/A21.15, Flanged Ductile-Iron Pipe with Ductile-Iron or Gray-Iron Threaded Flanges,<sup>2,3</sup>

ANSI/AWWA C116/A21.16, Protective Fusion-Bonded Epoxy Coatings for the Interior and Exterior Surfaces of Ductile-Iron and Gray-Iron Fittings for Water Supply Service,<sup>2,3</sup>

ANSI/AWWA C153/A21.53, Ductile Iron Compact Fittings for Water Service,<sup>2,3</sup>

ANSI/AWWA C600, Installation of Ductile-Iron Water Mains and Their Appurtenances, and<sup>2,3</sup>

ANSI/AWWA C606, Grooved and Shouldered Joints,<sup>2,3</sup>

NOTE 2—These specifications were prepared by appropriate subcommittees of American Water Works Association Committee A21 on Ductile Iron Pipe and Fittings. This committee was originally organized as an American National Standards Committee under the sponsorship of ASTM, American Gas Association (A.G.A), American Water Works Association (AWWA), and New England Water Works Association (NEWWA). The current sponsor is AWWA and the present scope of Committee A21 activity is to develop standards and manuals for ductile-iron and gray-iron fittings for use with such pipe. After these specifications were approved by Committee A21, they were approved as national standards by ANSI.

NOTE 3—The pipes described in these specifications have been designed for trench conditions and internal working pressures in accordance with the method developed by ANSI Standards Committee A21. These methods are described in ANSI/AWWA C150/A21.50, Thickness Design of Ductile-Iron Pipe.

<sup>2</sup> Available from the American National Standards Institute, 11 25 W. 42nd St., 13th Floor, New York, NY 10036.

<sup>3</sup> Available from American Water Works Assoc., 6666 W. Quincy Ave., Denver, CO 80235.

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)).*